



Boulogne-Billancourt, France,
21st February 2024

Subject: Use of anchor in firestop system Hilti CFS-C P – ETA-10/0404

Dear sender,

We would like to thank you for your confidence in us. Our team is at your service to advise you and to provide you with the best solution.

Hilti offers Through-Penetration Firestop Systems for wall and floor application in construction segments. One of our products is the Hilti Firestop Collar CFS-C P, covered by European Technical Assessment ETA 10/0404 (version April 30th, 2015),

We were advised to a misunderstanding in our current ETA version, based on an incorrect information given at page 26, section 2.3. Within the current ETA version, a screw size/rod size of M10 has been named, which is incorrect, as it cannot penetrate the necessary fixing hooks.

The hooks for collars size 125/10" up to 250/10" should be fixed in floors with either:

- M8 metal anchors, or
- M8 threaded rod with nut and washer, or
- Concrete screws anchors Hilti HUS-P ou HUS-H (anchor size 8).

We will correct anchor size M10 by M8 (8 mm of diameter) within the next ETA update.

With kind regards

Beatriz BOULLOSA ALLARIZ
PhD. Codes & Approvals Manager
Western Europe

Bouchra EL-HAWARI
Head of Engineering & Technical Marketing
Western Europe



Hilti France
126 rue Gallieni
92100 Boulogne-Billancourt

T +33 (0)8 25 01 05 05 | F +33 (0)8 25 02 55 55 | www.hilti.fr

S.A.S. au capital de 25.908.000 €
R.C.S. B 971 204 052 Nanterre | SIRET 971 204 052 01120